Certificate Number: AZ 69027372 Page: 0001



## **CERTIFICATE OF SUITABILITY**

Authorised marking: TUV-027372-E

TÜV Rheinland Australia Pty Ltd "Electrical Product Safety Certification (EPSC) Scheme", accredited by JAS-ANZ in accordance with ISO/IEC 17065, has issued this certificate under JAS-ANZ accreditation. The electrical equipment described hereunder has been evaluated and found to be electrically safe at the time of certification and met the minimum safety requirements contained in Australian Standard AS/NZS 3820 as of current. It is a requirement that all equipment supplied under this certificate shall be identical to the equipment as certified. The certificate holder may affix the above mentioned authorised marking on the product.

CERTIFICATE HOLDER: SUNTREE Electric Group Co., Ltd.

Xinguang Industrial Zone, Liushi Town, Yueqing City

Zhejiang P.R. China

**DESCRIPTION OF EQUIPMENT** 

Declared class: Non-declared

Product: Surface Mounted Switch Disconnector

Trade Name / Manufacturer: SUNTREE (Logo)

Model Number: PMAS50 series

**Ratings:** 250V~, 440V~, 50Hz, AC-22A, IP66

Ui = 500V, Uimp = 4kV, Ithe = 63A

lcm = 2.1kA, lcw = 1.5kA, 1s

Refer to CONTINUATION SHEET 1 for further details

**Standard:** AS 60947.3:2018

AS/NZS IEC 60947.1:2015

 Issue Date:
 29/11/2023

 Expiry Date:
 29/11/2028

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

JAS-ANZ

www.jas-anz.org\register

Grant Li

TUV Rheinland Australia Pty Ltd 182 Dougharty Road, Heidelberg West VIC 3081 Phone: +61 (3) 9450 1400

Email: certification@au.tuv.com
Website: www.au.tuv.com

Certificate Number:

AZ 69027372

Page: 0002



## **CERTIFICATE OF SUITABILITY**

Authorised marking:

TUV-027372-E

**CONTINUATION SHEET 1** 

**DESCRIPTION OF EQUIPMENT** 

Model No./Voltage (V)/Current (A)/No. of poles

PMAS50-20R-1/250/20/1

PMAS50-35R-1/250/35/1

PMAS50-63R-1/250/63/1

PMAS50-20R-2/440/20/2

PMAS50-35R-2/440/35/2

PMAS50-63R-2/440/63/2

PMAS50-20R-3/440/20/3

PMAS50-35R-3/440/35/3

PMAS50-63R-3/440/63/3

PMAS50-20R-4/440/20/4

PMAS50-35R-4/440/35/4

PMAS50-63R-4/440/63/4

(Rheimland

Issue Date: 29/11/2023 Expiry Date: 29/11/2028

Signed for and on behalf of TÜV Rheinland Australia Pty Ltd

Grant Li

JAS-ANZ

www.jas-anz.org\register

TUV Rheinland Australia Pty Ltd 182 Dougharty Road, Heidelberg West VIC 3081

Phone: +61 (3) 9450 1400 Email: certification@au.tuv.com Website: www.au.tuv.com