



Ref. Certif. No.

HU-002161

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Switch-disconnector

Name and address of the applicant

SUNTREE Electric Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing,
Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing,
Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Co., Ltd.
Xinguang Industrial Zone, Liushi Town, Yueqing,
Zhejiang, P.R. China

Note: When more than one factory, please report on page 2

Ratings and principal characteristics

AC-22A; 1P, 2P, 3P, 4P; 250VAC(1P), 440VAC(2P,3P,4P);
50/60Hz; Ie: 20A (x=20), 35A (x=35), 63A (x=63);
Icm:2,1kA; Icw:1,5kA, 1s; Ui:500V; Uimp:4,0kV;
Ithe:63A; IP66

Trademark (if any))

suntree

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

PMAS50-xR-y (x=20, 35 or 63, y=1, 2, 3 or 4)
(See general product information of the Test Report
for the meaning of "x", "y")Additional information (if necessary may also be
reported on page 2)

A sample of the product was tested and found
to be in conformity withIEC 60947-3:2008 + AMD1:2012 + AMD2:2015
IEC 60947-1:2007 + AMD1:2010 + AMD2:2014As shown in the Test Report Ref. No. which forms part
of this Certificate

1W170893

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., Division MEEI
H-1132 Budapest, Váci út 48/A-B
www.tuv.hu

Date: 2018-02-07

Signature:

Gabor Kassai



CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50394610 0001

Report No.: 50111457 001

Holder: **SUNTREE Electric Co., Ltd.**
Xinguang Industrial Zone, Liushi Town,
Yueqing City, Zhejiang
P. R. China

Product: Switch-disconnector
(Switch-disconnector)

Identification: Type Designation: PMAS50-xR-y
(x=20, 35 or 63)
(y=1, 2, 3 or 4)
(Suntree)
Serial No. : Engineering sample
Remark: Issued in conjunction with TÜV Rheinland license
R 50394607 0001.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 29.11.2017



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with.



SUNTREE Electric Co., Ltd.
Tony Liu
-
Xinguang Industrial Zone, Liushi
Town,
Yueqing City, Zhejiang
P. R. China

Date : 30.11.2017
Our ref. : WTH 01
Your ref.: T.L.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : AN 50394610 0001
Report No. : 50111457 001

Dear Tony Liu,


We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Jie Zhang

CC: SUNTREE Electric Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50413768 0001

Report No.: 50111457 002

Holder: **SUNTREE Electric Co., Ltd.**
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang
P. R. China

Product: Switch-disconnector
(Switch-disconnector)

Identification: Type Designation: PMAS50-xR-y
(x=20, 25, 32, 35 or 63)
(y=1, 2, 3 or 4)
(Suntree)
Serial No.: Engineering sample
Remark: Issued in conjunction with TÜV Rheinland license
R 50394607 0001-0002.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body



Date 02.08.2018

Jie Zhang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

SUNTREE Electric Co., Ltd.
Tony Liu
-
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang
P. R. China

Date : 02.08.2018
Our ref. : WTH 01
Your ref.: T.L.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : AN 50413768 0001
Report No. : 50111457 002

Dear Tony Liu,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Jie Zhang

CC: SUNTREE Electric Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50435075 0001

Report No.: 50111457 003

Holder: **Suntree Electric Group Co., Ltd.**
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Product: Switch-disconnector
(Switch-disconnector)

Identification: Type Designation: PMAS50-xR-y
(x=20, 25, 32, 35 or 63)
(y=1, 2, 3 or 4)
(Suntree)
Serial No. : Engineering sample
Remark: Issued in conjunction with TÜV Rheinland license
R 50394607 0001-0003.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 08.08.2019



TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. CE

Suntree Electric Group Co., Ltd.
Tony Liu
-
Xinguang Industrial Zone,
Liushi Town, Yueqing City,
Zhejiang Province 325604
P. R. China

Date : 08.08.2019
Our ref. : WTH 01
Your ref.: T.L.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Switch-disconnector
Model Designation : See Certificate
Certificate No. : AN 50435075 0001
Report No. : 50111457 003

Dear Tony Liu,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body


Hao Zheng

CC: Suntree Electric Group Co., Ltd.

Enclosure

证书的详细资料请登陆www.tuvdotcom.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询