

CERTIFICATE

of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50506734 0001

Report No.: CN21WAW0 001

Holder: **SUNTREE Electric Group Co., Ltd.**
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Product: **Surge Protector**
(Surge Protective Device for PV systems)

Identification: Type Designation : SUP2-PV, SUP4-S40
(SUNTREE)
Serial No. : Engineering Samples

Remark:

This certificate issued in conjunction with R50506706 0001

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Certification Body



Bo Liu

Date 31.08.2021

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with.



TÜV Rheinland (China) Ltd.
Member of TÜV Rheinland Group



SUNTREE Electric Group Co., Ltd.
Maggie Liu

Date : 31.08.2021
Our ref. : YangYongM 01
Your ref.: M.L.

Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Surge Protective Device for PV systems
Model Designation : See Certificate
Certificate No. : AN 50506734 0001
Report No. : CN21WAW0 001

Dear Maggie Liu,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Enclosed you will find the certificate of approval.

If cancellation of the certificate is submitted by November 15 in a given year, no fee will be charged for the following year.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

Please contact our office for approval of your new products.

With kind regards,

Certification Body

Bo Liu

CC: SUNTREE Electric Group Co., Ltd.

Enclosure

证书的详细资料请登录<https://www.certipedia.com>查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

TÜV Rheinland (China) Ltd.
Room 301, 3F and Room 1203, 12F,
Building 4, No. 15, Ronghua South Road,
Beijing Economic-Technological
Development Area, Beijing
www.chn.tuv.com

莱茵检测认证服务(中国)有限公司
北京市北京经济技术开发区
荣华南路15号院4号楼3层301室
12层1203室
邮编: 100176
www.chn.tuv.com

Tel: 86 10 8524 2222
Fax: 86 10 8524 2200
Hotline: 400 883 1300
800 999 3668
GC Service mailbox: service-gc@tuv.com

电话: 86 10 8524 2222
传真: 86 10 8524 2200
热线: 400 883 1300
800 999 3668
大中华区服务邮箱: service-gc@tuv.com



Ref. Certif. No.

HU-003466

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

PV Surge Protective Device

Name and address of the applicant

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Ratings and principal characteristics

UCPV: 1500 VDC, In: 20 kA, Imax: 40 kA, PV T2,
Itotal (8/20 μ s): 40 kA, Up: 5.0 kV, ISCPV: 10A

Trademark (if any)

Suntree (logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SUP2-PV, SUP4-S40

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN21JCTT 001


A sample of the product was tested and found to be in conformity with

IEC 61643-31:2018

As shown in the Test Report Ref. No. which forms part of this Certificate

CN21JCTT 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2021-09-01

Signature:

Wencai Zhang