



Product Service

CERTIFICATE

No. B 12 09 82234 004

Holder of Certificate: YUEQING XINCHI ELECTRIC & SCIENCE TECHNOLOGY CO.,LTD.

MALUJIAO Village, NORTH BAIXIANG
 325603 YUEQING, ZHEJIANG
 PEOPLE'S REPUBLIC OF CHINA

Production Facility(ies): 82234

Certification Mark:



Product: **Switches**
Switch-Disconnectors

Model(s): **SISO-32/32, SISO-32/25, SISO-32/20,**
SISO-32/16, SISO-32/10

Parameters:

Rated voltage:	DC1000V
Rated current:	10A, 16A, 20A, 25A, 32A
Number of Phases:	4
Utilization of category:	DC-21B
Rated short-time withstand current I _{cw} :	1000A/1s
Rated short-time making capacity I _{cm} :	1700A

Tested according to: EN 60947-3:2009

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition the certification holder must not transfer the certificate to third parties. See also notes overleaf.

Test report no.: 7041012114001-00

Date, 2012-09-28
 Page 1 of 1

 (Yi Zhu)

