



Ref. Certif. No.

HU-003356

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Moulded Case Circuit Breaker

Name and address of the applicant

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Ratings and principal characteristics

Ui: 800V; Uimp: 8kV; Reference temperature: +40°C; Cat.A;
Ue: AC400V 50/60Hz; In:10/16/20/25/32/40/50/63A; 3P, 3P+N, 4P;
Ics: 12,5kA (SM8-63C); 22kA (SM8-63L); 35kA (SM8-63M);
Icu: 25kA (SM8-63C); 35kA (SM8-63L); 50kA (SM8-63M)

Trademark (if any)

SUNTREE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SM8-63C , SM8-63L , SM8-63M

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN2188NO 001.

A sample of the product was tested and found to be in conformity with

IEC 60947-2:2016+A1

As shown in the Test Report Ref. No. which forms part of this Certificate

CN2188NO 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web:www.tuv.com

Date: 2021-03-23

Signature:

Wencai Zhang

C E R T I F I C A T E



of Conformity
Low Voltage Directive 2014/35/EU

Registration No.: AN 50498176 0001

Report No.: CN21BRXR 001

Holder: **SUNTREE Electric Group Co., Ltd.**
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Product: Moulded case circuit breaker
(MCCB)

Identification: Type Designation: SM8-63C # SM8-63L # SM8-63M (Suntree)

Serial No. : Engineering sample

Remark: Issued in conjunction with TÜV Rheinland license
R 50497350 0001.

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 29.03.2021



Hao Zheng

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

CE The CE marking may be used if all relevant and effective EC Directives are complied with. **CE**

SUNTREE Electric Group Co., Ltd.
Xufen Liu

Date : 29.03.2021
Our ref. : DJL 01
Your ref.: L.X.F.

Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Ref : R TÜV-Mark Approval

Type of Equipment : MCCB
Model Designation : See Certificate
Certificate No. : R 50497350 0001
Report No. : CN21BRXR 001

Dear Xufen Liu,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body


Hao Zheng

cc: SUNTREE Electric Group Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询