

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50497350

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
L.X.F.

Unser Zeichen *Our Reference*
01-DJL-CN21BRXR 001

Ausstellungsdatum *Date of Issue*
29.03.2021 (day/mo/yr)

Genehmigungsinhaber *License Holder*

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 60947-2:2017+A1

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Moulded case circuit breaker (MCCB)

Type Designation	: 1) SM8-63C ; 2) SM8-63L ; 3) SM8-63M	8
Reference Temperature	: +40°C	
Selectivity Category	: A	
Type of Release	: Thermo-magnetic	
Number of Poles	: 3P; 3P+N; 4P	
Rated Operation Voltage(Ue)	: AC400V	
Rated Current(In)	: 10/16/20/25/32/40/50/63A	
Rated Ultimate Short-circuit Breaking Capacity(Icu)	: 1)25kA; 2)35kA; 3)50kA	
Rated Service Short-circuit Breaking Capacity(Ics)	: 1)12,5kA; 2)22kA; 3)35kA	
Rated Insulation Voltage(Ui)	: 800V	
Rated Impulse Withstand Voltage(Uimp)	: 8,0kV	
Suitability for Isolation	: Yes (3/4P); No (3P+N)	
Pollution Degree	: 3	

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle



Hao Zheng

SUNTREE Electric Group Co., Ltd.
Xufen Liu

Date : 29.03.2021
Our ref. : DJL 01
Your ref.: L.X.F.

Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : MCCB
Model Designation : See Certificate
Certificate No. : AN 50498176 0001
Report No. : CN21BRXR 001

Dear Xufen Liu,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Hao Zheng

CC: SUNTREE Electric Group Co., Ltd.

Enclosure

证书的详细信息请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询