

CERTIFICATE



of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50538055 0001

Report No.: CN22LUKS 001

Holder: SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Product: Fuse Link
(Low-voltage Fuse for PV System)

Identification:

Fuse-link	
Type Designation	: SRF-30; CHF-30 (Suntree)
Rated Voltage	: 1000V DC
Rated Current	: 6A; 8A; 10A; 12A; 15A; 16A; 20A; 25A; 30A and 32A
Serial No.	: Engineering sample
Remark:	Certificate issued in conjunction with R50545060 0001

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.

Certification Body

Date 30.05.2022



Yang Yongming

Yongming Yang

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

SUNTREE Electric Group Co., Ltd.
Xufen Liu

Date : 30.05.2022
Our ref. : ZWC 01
Your ref.: L.X.F.

Xinguang Industrial Zone,
Liushi Town, Yueqing City
Zhejiang
P.R. China

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Low-voltage Fuse for PV System
Model Designation : See Certificate
Certificate No. : AN 50538055 0001
Report No. : CN22LUKS 001

Dear Xufen Liu,

We herewith confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Enclosed please find your Certificate of Conformity.

We appreciate your kind support and would like to offer our assistance and continuous services in the future.

With kind regards,

Certification Body



Yongming Yang

CC: SUNTREE Electric Group Co., Ltd.

Enclosure

证书的详细资料请登陆www.certipedia.com查阅,或拨打我司客服热线800 999 3668 / 400 883 1300咨询



Ref. Certif. No.

HU-003944

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Low-voltage Fuses for PV system

Name and address of the applicant

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the manufacturer

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Name and address of the factory

SUNTREE Electric Group Co., Ltd.
Xinguang Industrial Zone,
Liushi Town, Yueqing City, Zhejiang, P.R. China

Ratings and principal characteristics

Rated voltage: 1000V DC;
Rated current: 6A, 8A, 10A, 12A, 15A, 16A, 20A, 25A, 30A, 32A
Rated breaking capacity: 20kA; gPV;
Size: 10x38

Trademark (if any)

Suntree (logo)

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

SRF-30 ; CHF-30

Additional information (if necessary may also be reported on page 2)

Detailed information refer to test report CN22K1QV 001

A sample of the product was tested and found to be in conformity with

IEC 60269-6:2010
IEC 60269-1:2006+A1+A2

As shown in the Test Report Ref. No. which forms part of this Certificate

CN22K1QV 001

This CB Test Certificate is issued by the National Certification Body



TÜVRheinland®

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2022-05-26

Signature:

Wencai Zhang